

Our Ref: LTR/10732/2/AV

CERTIFICATE

12th March 2013

This is to certify that at the request of Xiamen Grace Solar Technology Co. Ltd, Dome Consulting (Aust) Pty Ltd have reviewed the componentry used for the installation of Sunrack Solar Panels to existing roof structures.

The elements which were to be checked include:

- Ø Supporting panel rail***
- Ø Mounting clips***
- Ø Roof hooks***
- Ø Adapters***
- Ø Fixing screws and bolts***
- Ø Tri-angle systems***

The check included a review of Australia wide wind loading conditions including Cyclonic conditions, in accordance to AS1170.2/Amdt2/2012.12.24.

Solar Panel Restrict on 'D6' Conditions - Refer to the AMDT2 DEC 2012.

The general arrangement of the rails and supports for regions throughout Australia is to be provided by Xiamen Grace Solar Technology Co. Ltd and to comply with Dome Consulting (Aust) Pty Ltd Structural Report 10732-001 Dated 20/06/2012.

The review has determined that all the above mentioned supporting componentry was found to be acceptable.

Should you have any further queries please do not hesitate to contact me.

Yours faithfully,
FOR & ON BEHALF OF DOME CONSULTING PTY LTD



Robert Cilia
BE (Civil) RBP RPEQ TBP